SPECIFICATIONS FR0943986 Page 1 of1

NO.	DESCRIPTION	CHECK IF AS SPECIFIED	DESCRIBE FULLY IF NOT AS SPECIFIED
1.	Trutest 800, Conventional and Intelligent System Detector Test Equipment with Telescopic pole to be used on a Simplex system		
	MAXIMUM working height 20 ft.		
	Average test time: 120 seconds		
	Average cleaning time: 120 seconds		
	Average calibration time: 40 seconds		
	Maximum obscuration for Ionization 4.00 % / ft		
	Maximum Obscuration for Photoelectric 6.00 % / ft		
	Resolution: 0.01% / ft		
	Average Battery Life: 8-10 hrs testing on a full charge		
	Calibration: Auto Self-Calibrates before each test		
	Operating Temp. 50 Degrees F. to 95 Degrees F		
	Humidity between 0-85%		
	Max Weight: 7 pounds incl. aerosol canister		
	Average Testing per aerosol Canister (100)		
	Aerosol: Environmentally Friendly, non-Flammable,		
	non-Toxic,		
	Safety Data Sheet Available		
	1 Year Minimum Warranty		

SPECIFICATIONS FR0943986

Page 2 of1

2	Solo 461 Cordless Heat Detector Tester	
	For Heat Testing	
	Battery powered UL listed Charger included	
	Suits Fixed Temperature, Rate-of-rise and combination detectors	
	Detector manufacturer approved	
	Heat is directed horizontally at the sensor	
	Comes with two battery batons that fit inside Solo	
	poles and a fast charger	
	Cross Air Technology (CAT)	
	Rechargeable at vehicle	
	No flame	
	1 year Min. Warranty	
3	SOLO A4 SMOKE DETECTOR TESTER	
	Oil free formulation	
	No lasting residue	
	Detector component compatibility	
	Non-Flammable	
	UL listed	
	Can size min. 10.0 oz	